Approved For Release 2005/11/17 : CIA-RDP61-00901A000300010025-0

FLOOR PLAN

17-34 Sink in closet
100 foot candle light
Uses adjoining secure area

50 —

22 Vault

23 Sink with drain trough
100 foot candle light
Extra electrical outlets for equipment
Acoustical treatment to deaden noise

24 Extra electrical outlets for equipment
100 foot candle light
Acoustical treatment to deaden noise
Sprinkler system

25 Exhaust (paint spray)
100 foot candle light
~~explosion proof~~ lighting fixtures
Sprinkler system
Acoustical treatment to deaden noise

26 Sprinkler system

54 — 34 Sink
Extra electrical outlets for equipment
100 foot candle light

58 — 28 Extra electrical outlets for equipment
11' ceiling for Sodium projector
Sink
100 foot candle light
Exhaust

JOB NO. BOX NO. FLD NO. DOC. NO. 1 NO CHANGE
IN CLASS. DECLASS. X CLASS CHANGED TO: TS S C NEXT REV DATE 10 REVIEWER TYPE DOC 39
NO. PGS. 2 CREATION DATE ORIG COMP 32 OPI 36 ORIG CLASS M
REV CLASS REV COORD AUTH: HR 70-3

Approved For Release 2005/11/17 : CIA-RDP61-00901A000300010025-0

Approved For Release 2005/11/17 : CIA-RDP61-00901A000300010025-0

5F - 29 Vault

74 - 19 Extra electrical outlets for light table
Double door to accomodate large tables
100 foot candle light
Alarm (space is secure area)

75 - 12 Sink
Extra electrical outlets for equipment
Acoustical treatment & double wall
Exhaust

13 Vault

14 Extra electrical outlets for light tables
Large door to accomodate light tables
100 foot candle light

STAT

Note -

Normal lighting in building is 50 foot candles

Approved For Release 2005/11/17 : CIA-RDP61-00901A000300010025-0